



REopt Lite Beta Version Introduction to FEMP & NREL's New Web Tool



Rachel Shepherd, Federal Energy Management Program
Emma Elqvist, National Renewable Energy Laboratory




The REopt Model and It's History

FEMP uses REopt to help agencies screen and evaluate renewable energy opportunities and focus resources on projects that have economic and technical viability.

REopt has been used to assess opportunities at over 10,000 sites, REopt analyses have supported decisions that led to more than 260 MW of renewable energy development.

- US Forest Service
- National Park Service
- Fish and Wildlife Service
- Department of Defense
- Department of Energy
- Department of Commerce
- Department of State
- General Services Administration
- US Department of Veteran's Affairs
- Department of Homeland Security
- US Department of Agriculture
- US Bureau of Reclamation
- Bureau of Land Management
- Indian Health Service
- Western Area Power Administration
- Navajo Generating Station



Developing the REopt Lite Web Tool



Mission

Provide access to a decision support tool for site-specific, optimized, and integrated analysis

Vision

Advance data-driven decision-making and deployment of renewable energy and energy storage technologies



2017



REopt Lite: Sizing Solar+Storage for Savings and Resiliency

Emma Elgqvist¹, Rachel Shepherd²

November 15, 2017

¹National Renewable Energy Laboratory ²Federal Energy Management Program

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.

Optimization • Integration • Automation

Master Planning


- Portfolio prioritization
- Cost to meet goals



Cost-effective RE at Army bases

Economic Dispatch


- Technology types & sizes
- Optimal operating strategies



Cost-optimal Operating Strategy

Resiliency Analysis

- Microgrid dispatch
- Energy security evaluation



Extending Resiliency with RE

REopt Lite Web Tool

- Publicly available beta version of REopt Lite launched September 2017
- Evaluates the economics of grid-connected PV and battery storage at a site
- Allows building owners to identify the system sizes and battery dispatch strategy that minimize their life cycle cost of energy



Step 1: Select Your Technology

Do you want to evaluate PV, battery, or both?

Step 2: Enter Your Data

Enter information about your site and adjust the default values as needed to see your results.

Site and Utility (required)

* Required field

* Site location

* Load profile Simulated
 Custom Load Profile

* Type of building

* Annual energy consumption (kWh)

* Electricity rate
URDB Rate Details

[Show more inputs](#) [Reset to default values](#)

<https://reopt.nrel.gov/tool>

[Get Results](#)

Five Required Site Specific Inputs

Additional Inputs Can Be Edited, Or Left As Defaults

Site and Utility (required)

* Required field

* Site location [?](#) Palmdale, CA, United States

* Load profile [?](#) Simulated
 Custom Load Profile

* Type of building [?](#) Retail Store

* Annual energy consumption (kWh) [?](#) 500000

* Electricity rate [?](#) Southern California Edison Co: Time of Use, Gen
[URDB Rate Details](#)

[+](#) Show more inputs [↺](#) Reset to default values

Financial [+](#)

PV [+](#)

Battery [+](#)

Resilience [+](#)

[Get Results](#) [↺](#)

Financial [+](#)

Host real discount rate (%) [?](#) 6.8%

Electricity escalation rate (%) [?](#) 0.5%

[+](#) Show more inputs [↺](#) Reset to default values

Summary Results Include System Sizes and Savings

Results for Your Site

These results from REopt Lite summarize the economic viability of PV and battery storage at your site. You can edit your inputs to see how changes to your energy strategies affect the results.



[Edit Inputs](#)



Your recommended solar installation size ?

392 kW
PV size

Measured in kilowatts (kW) of direct current, this recommended size minimizes the life cycle cost of energy at your site.



Your recommended battery power and capacity ?

93 kW
battery power

342 kWh
battery capacity

This system size minimizes the life cycle cost of energy at your site. The battery power and capacity are optimized for economic performance.



Your potential life cycle savings (20 years) ?

This is the net present value of the savings (or costs if negative) realized by the project based on the difference between the life cycle energy cost of doing business as usual compared to the optimal case.


\$238,450

Additional Results Output

Economics Summary and Hourly Dispatch Graph

	Business As Usual ?	Optimal Case ?
System Size, Energy Production, and System Cost		
PV Size ?	0 kW	392 kW
Annualized PV Energy Production ?	0 kWh	680,826 kWh
Battery Power ?	0 kW	93 kW
Battery Capacity ?	0 kWh	342 kWh
DG System Cost (Net CAPEX + O&M) ?	\$0	\$526,342
Energy Supplied From Grid in Year 1 ?	1,000,000 kWh	358,623 kWh
Year 1 Utility Cost — Before Tax		
Utility Energy Cost ?	\$118,263	\$34,216
Utility Demand Cost ?	\$40,008	\$18,623
Utility Fixed Cost ?	\$3,110	\$3,110
Utility Minimum Cost Adder ?	\$0	\$0
Life Cycle Utility Cost — After Tax		
Utility Energy Cost ?	\$857,868	\$248,200
Utility Demand Cost ?	\$290,213	\$135,089
Utility Fixed Cost ?	\$22,562	\$22,562
Utility Minimum Cost Adder ?	\$0	\$0
Total System and Life Cycle Utility Cost — After Tax		
Life Cycle Energy Cost ?	\$1,170,644	\$932,194
Net Present Value ?	\$0	\$238,450

[Download ProForma Spreadsheet](#)



Task	Description
API	Expose API and provide wiki to call model via API
Resiliency	Expand resiliency analysis <ul style="list-style-type: none">• Build up a critical load profile based on equipment• Model existing diesel and PV systems• Design system based on probability of sustaining critical load• Incorporate the value of lost load
User data storage	Allow user to retrieve and edit stored inputs for future analysis
Wind	Add wind technology, purchase license for wind dataset
Custom utility rate	Allow user to enter custom utility rate tariff
Report	Downloadable sensitivity analysis report and dispatch strategy
User resources	Training materials and case studies

REopt Website
<https://reopt.nrel.gov/>

Emma Elgqvist
emma.elgqvist@nrel.gov

Rachel Shepherd
rachel.shepherd@ee.doe.gov

www.nrel.gov



Backup Slides


- REopt website: <https://reopt.nrel.gov/>
- REopt Lite web tool: <https://reopt.nrel.gov/tool>
- REopt technical report:
<https://www.nrel.gov/docs/fy17osti/70022.pdf>
- REopt fact sheet:
<http://www.nrel.gov/docs/fy14osti/62320.pdf>

REopt Platform vs. Web Tool Phase 1 Capabilities



	Current Platform Capabilities	Phase 1 Web Tool Capabilities
Technologies Evaluated	PV, SHW, SVP, Wind, Biomass, LFG, WTE, GSHP, Storage, Conventional reciprocating and combustion turbine generators	PV + Storage
Sites Evaluated	Multi-site	Single site
Load Types	Electric, thermal, interval data from actual load profiles or simulated from DOE commercial reference buildings, others for customized analysis	Electric only interval data or simulated from DOE commercial reference buildings
Rate Tariffs	Blended rates, simple rate tariffs, and custom rates entered by user	Rate tariffs selected from URDB
Resiliency Analysis	Simple outage analysis or complex stochastic outage modeling	Simple outage analysis


REopt Inputs and Output



Project Example: Identifying & Prioritizing Projects across a Portfolio



REopt portfolio screening can help:

- Identify & prioritize cost-effective projects to minimize lifecycle cost of energy or achieve net zero
- Estimate cost of meeting renewable energy goals



Sites Evaluated	696
Cost-Effective PV	306
Size	38.79 MW
NPV	\$37 million
RE Generation	64.7 GWh
RE Penetration	10.5 %


- Determine economically optimal PV + storage system size & dispatch using:
 - 15-minute electric load
 - Southern California Edison utility tariff TOU-8
- Results show 12.4 MW PV + 2.4 MW:3.7 MWh storage can provide \$19.3 million NPV
- Battery is only economical when paired with PV at this site due to wide peaks
- Optimal battery dispatch strategy reduces all three demand charges



Project Example: Extending Survivability

NREL evaluated thousands of random grid outages and durations throughout the year and compared number of hours the site could survive with a diesel generator and fixed fuel supply vs. generator augmented with PV and battery

	<u>Generator</u>	<u>Solar PV</u>	<u>Storage</u>	<u>Lifecycle Cost</u>	<u>Outage</u>
1. Base case	2.5 MW	-	-	\$20 million	5 days
2. Lowest cost solution	2.5 MW	625 kW	175 kWh	\$19.5 million	6 days
3. Proposed system	2.5 MW	2 MW	500 kWh	\$20 .1million	9 days



Simple Resiliency Evaluation

Simple Resiliency Inputs

 Resilience 

Outage start 

Outage duration (hours) 

Critical load factor 

 Reset to default values

Simple Resiliency Outputs

Evaluate the amount of time that your system can survive grid outages.

	Business As Usual 	Optimal Case 	Difference 
Average Resiliency (hours) 	0 hours	3 hours	3 hours
Minimum Resiliency (hours) 	0 hours	0 hours	0 hours
Maximum Resiliency (hours) 	0 hours	21 hours	21 hours